

Modbus RTU to IEC104 protocol conversion

Setup

This article describes WCC Lite configuration steps to enable Modbus TCP protocol conversion to IEC 104.



Before you begin, make sure you have completed all physical installation work according to the manufacturer's installation instructions.

Set up your computer and connect the Ethernet cable to the WCC Lite ETH0 port. Log in with default credentials and set up basic required settings (name, network, users, etc.). You can find configuration tutorials in [How to articles](#).

After setup, download the configuration template from the device (Protocol Hub → Configuration → Template configuration Download)
Or download the configuration example from this article.

To prepare the configuration, fill in the information in both the Devices and Signals sheets:

Configuring Devices

Add a connected ABB meter with the Modbus RTU protocol required information:

| name | description | device_alias | enable | protocol | id | device | baudrate | databits |
|----------------|-------------|--------------|--------|------------|----|--------|----------|----------|
| From ABB Meter | ABB B21 | B21 | 1 | Modbus RTU | 1 | PORT2 | 9600 | 8 |

| stopbits | parity | flowcontrol | scan_rate_ms | serial_delay | retry_count |
|----------|--------|-------------|--------------|--------------|-------------|
| 1 | none | none | 5000 | 200 | 3 |

Add SCADA working on IEC104 protocol required information:

| name | description | device_alias | enable | protocol | bind_address | host | port |
|----------|-------------|--------------|--------|-----------------------|--------------|------------------------------|------|
| To SCADA | | iec104 | 1 | IEC 60870-5-104 slave | 0.0.0 | 192.168.1.10 192.168.71.1 | 2404 |

| asdu_size | cot_size | ioa_size | rwt | swt | t1 | t2 | t3 | time_sync | message_size | cache_size |
|-----------|----------|----------|-----|-----|----|----|-----|-----------|--------------|------------|
| 2 | 2 | 3 | 8 | 12 | 45 | 30 | 200 | 1 | 249 | 100 |

You can find more options and descriptions of the settings in the [Device configuration](#) article.

Configuring Signals

Add connected meter measurements information. Use the meter manual for information and addresses ([tag_job_todo](#)).

| signal_name | device_alias | signal_alias | enable | multiply | log | job_todo | tag_job_todo | number_type |
|---------------|--------------|--------------|--------|----------|-----|-----------|--------------|-------------|
| Voltage | B21 | U | 1 | 0.1 | 1 | 3;23296;2 | 3;23296;2 | UNSIGNED32 |
| Current | B21 | I | 1 | 0.01 | 1 | 3;23308;2 | 3;23308;2 | UNSIGNED32 |
| Active power | B21 | P | 1 | 0.00001 | 1 | 3;23316;2 | 3;23316;2 | SIGNED32 |
| Frequency | B21 | F | 1 | 0.01 | 1 | 3;23340;1 | 3;23340;1 | UNSIGNED16 |
| Power factor | B21 | Cos | 1 | 0.001 | 1 | 3;23354;1 | 3;23354;1 | SIGNED16 |
| Active import | B21 | E | 1 | 0.01 | 1 | 3;20480;4 | 3;20480;4 | FLOAT |

💡 job_todo -Request to send according to Modbus specification without device address and checksum;

💡 tag_job_todo - a subset of the **job_todo** field, exact address of measurement (tag)

Add **IEC104** master signals information:

| signal_name | device_alias | signal_alias | source_device_alias | source_signal_alias |
|--------------|--------------|-----------------|---------------------|---------------------|
| Voltage | iec104 | tag-iec104-1001 | B21 | U |
| Current | iec104 | tag-iec104-1002 | B21 | I |
| Active power | iec104 | tag-iec104-1003 | B21 | P |
| Frequency | iec104 | tag-iec104-1004 | B21 | F |

| | | | | |
|---------------|--------|-----------------|-----|-----|
| Power factor | iec104 | tag-iec104-1005 | B21 | Cos |
| Active import | iec104 | tag-iec104-1006 | B21 | E |

| enable | log | units | multiply | gi | common_address | info_address | data_type |
|--------|-----|-------|----------|----|----------------|--------------|-----------|
| 1 | 1 | V | 1.0 | 1 | 1 | 1001 | 13 |
| 1 | 1 | A | 1.0 | 1 | 1 | 1002 | 13 |
| 1 | 1 | kW | 1.0 | 1 | 1 | 1003 | 13 |
| 1 | 1 | Hz | 1.0 | 1 | 1 | 1004 | 13 |
| 1 | 1 | | 1.0 | 1 | 1 | 1005 | 13 |
| 1 | 1 | kWh | 1.0 | 1 | 1 | 1006 | 13 |

Other examples with the Rail350 meter


 The video covers only 1.5 firmware version.

<https://www.youtube.com/embed/FdeyXs79Vww>

Uploading the Configuration

After configuring all devices and signals, follow these steps to check and upload the configuration using the WCC Excel Utility:

1. Download and run WCC Excel Utility.
2. Select the firmware version from the drop-down menu.
3. Select the Excel file from your computer and click *Convert*.
4. Check if no events in red color occur. If so, edit the Excel file according to the event text and repeat Step 2.
5. Enter the Host and credentials of WCC Lite, click connect and then *Upload configuration*.



Another method to upload the configuration is via the web interface:

1. Access the WCC Lite interface via your browser. The default IP address is 192.168.1.1. Enter credentials:

Authorization Required

Please enter your username and password.

| | |
|----------|--------------------------|
| Username | <input type="text"/> |
| Password | <input type="password"/> |

Login **Reset**

2. Upload the Excel configuration:

| PROTOCOL HUB | STATUS | SYSTEM | SERVICES | NETWORK | USERS | LOGOUT (ROOT) |
|----------------------|------------------|-----------|----------------------|-----------------|---------------|---------------|
| CONFIGURATION | IMPORTED SIGNALS | EVENT LOG | PROTOCOL CONNECTIONS | PROTOCOL LOGGER | SCRIPT-RUNNER | |

Protocol configuration

IMPORT PROTOCOL CONFIGURATION

Here you can import Excel configuration file. Up to 1000 signals are allowed. All previous signals will be replaced.

| | | |
|-----------------------------|---|---|
| Configuration file: | <input type="button" value="Choose File"/> No file chosen | <input type="button" value="Import configuration"/> |
| PLC (IEC-61499) Boot file: | <input type="button" value="Choose File"/> No file chosen | <input type="button" value="Import FBOOT file"/> |
| IEC61850 Client model file: | <input type="button" value="Choose File"/> No file chosen | <input type="button" value="Import client model file"/> |
| IEC61850 Server model file: | <input type="button" value="Choose File"/> No file chosen | <input type="button" value="Import server model file"/> |

3. After a successful upload, the configuration will appear under the **DOWNLOAD CONFIGURATION** tab:

DOWNLOAD CONFIGURATION

Current configuration (config-elseta-wcc-Comlynx.xlsx):
Last changed: 2024-11-10 01:44:14

[Download](#)

Template configurations:

[Download](#)

4. If any errors occur during the upload, follow the error messages, fix them according to Excel utility guidelines.

Files

1. ABB meter manual [Download](#)
2. WCC Excel Utility [Download](#)
3. Example of configuration file [Download](#)

⌚Revision #31
★Created 15 October 2020 13:27:39 by Matas
🕒Updated 9 April 2025 07:47:36 by Gabriele