

16.13 M-Bus

Overview

M-Bus or Meter-Bus is a protocol for the remote reading of water, gas, or electricity meters. M-Bus is also usable for other types of consumption meters, such as heating systems or water meters. The M-Bus interface is made for communication on two wires, making it cost-effective. M-bus over TCP is also supported. When configured, meters will deliver the data they have collected to a WCCLite RTU that is connected at periodic intervals (scan_rate_ms) to read all utility meters.

Configuration

M-Bus parameters for *Device* tab

Parameter	Type	Description	Required	Default value (when not specified)	Range	
					Min	Max
name	string	User-friendly device name	Yes			
description	string	Description of a device	No			
device_alias	string	Alphanumeric string to identify a device	Yes			
enable	boolean	Enabling/disabling a device	No	1	0	1
protocol	string	Protocol to be used.	Yes		mbus serial, mbus tcp	
scan_rate_ms	integer	All reads and writes will be executed within the timeframe in milliseconds.	No	10000		
poll_delay_ms	integer	Minimum time delay in milliseconds to wait before sending any data on port.	No	200		
timeout_ms	integer	Timeout of waiting for an incoming response in milliseconds	Yes		0	60000
address	integer	Device address	Yes			
device	string	Communication port	Yes (for serial)		PORT1	PORT2
baudrate	integer	Communication speed, baud/s	No (for serial)	9600	300, 600, 1200, 2400, 4800, 9600, 19200, 38400, 57600, 115200	
databits	integer	Data bit count for communication	No (for serial)	8	6	9
stopbits	integer	Stop bit count for communication	No (for serial)	1	1	2

parity	string	Communication parity option	No (for serial)	none	none, even, odd	
serial_close_delay	integer	Delay before closing the serial connection.	No (for serial)	400		
ip	string	The IP address of the TCP slave device	Yes (for TCP).			
port	integer	TCP communication port	Yes (for TCP)		0	65535

M-Bus parameters for the *Signals* tab

Parameter	Type	Description	Required	Default value (when not specified)	Range	
					Min	Max
signal_name	string	User-friendly signal name	Yes			
device_alias	string	Device alias from a Devices tab	Yes			
signal_alias	string	Unique alphanumeric name of the signal to be used	Yes			
enable	boolean	Enabling/disabling of an individual signal	No	1	0	1
log	integer	Enable logging in the event log	No	0		
number_type	string	Type of a number (FLOAT, DOUBLE, DIGITAL, etc.)	Yes			
job_todo	string	Tag job as single or multiple comma-separated OBIS codes	Yes			
tag_job_todo	string	Tag sub job	Yes			

🔄Revision #7

★Created 22 March 2022 14:40:38

✎Updated 29 March 2022 14:08:05